



Experience is the solution

314 North Pearl Street ♦ Albany, New York 12207
(800) 848-4983 ♦ (518) 434-4546 ♦ Fax (518) 434-0891

April 15, 2021

KeithDomermuth
Berne Knox Westerlo School District
1738 Helderberg Trail
Berne, NY 12308

TEL: (518) 872-1117

Work Order No: 210406028
PO#: 210310

RE:

Elementary Lead

Dear KeithDomermuth:

Adirondack Environmental Services, Inc received 82 samples on 4/6/2021 for the analyses presented in the following report.

Please see case narrative for specifics on analysis.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,

Tara Daniels
Laboratory Director

ELAP#: 10709

Adirondack Environmental Services, Inc

CASE NARRATIVE

Beme Knox Westerlo School District

Date: 15-Apr-21

Elementary Lead

Lab WorkOrder: 210406028

Sample containers were supplied by Adirondack Environmental Services.

Definitions - RL: Reporting Limit DF: Dilution factor

Qualifiers:	ND : Not Detected at reporting limit	C: CCV below acceptable Limits
	J: Analyte detected below quantitation limit	C+: CCV above acceptable Limits
	B: Analyte detected in Blank	S: LCS Spike recovery is below acceptable limits
	X : Exceeds maximum contamination limit	S+: LCS Spike recovery is above acceptable limits
	H: Hold time exceeded	Z: Duplication outside acceptable limits
	N: Matrix Spike below acceptable limits	T : Tentatively Identified Compound-Estimated
	N+: Matrix Spike is above acceptable limits	E :Above quantitation range-Estimated

Note : All Results are reported as wet weight unless noted

The results relate only to the items tested. Information supplied by the client is assumed to be correct.

Adirondack Environmental Services, Inc

Date: 15-Apr-21

CLIENT: Berne Knox Westerlo School District**LabWork Order:** 210406028**Project:****PO#:** 210310

Elementary Lead

Lab SampleID: 210406028-001**Collection Date:** 4/5/2021**Client Sample ID:** ES207 Faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021
------	----	-----	--	------	---	-----------

Lab SampleID: 210406028-002**Collection Date:** 4/5/2021**Client Sample ID:** ES 204 DF**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 6:32:27 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-003**Collection Date:** 4/5/2021**Client Sample ID:** ES 32 2nd Floor Boy's Left**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 6:36:11 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-004**Collection Date:** 4/5/2021**Client Sample ID:** ES 32 2nd Floor Boy's Right**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 6:39:56 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-005**Collection Date:** 4/5/2021**Client Sample ID:** ES 206 DF**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 6:43:41 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 15-Apr-21

CLIENT: Berne Knox Westerlo School District**LabWork Order:** 210406028**Project:****PO#:** 210310

Elementary Lead

Lab SampleID: 210406028-006**Collection Date:** 4/5/2021**Client Sample ID:** ES 207 DF**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 6:47:24 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-007**Collection Date:** 4/5/2021**Client Sample ID:** ES 205 DF**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 6:51:06 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-008**Collection Date:** 4/5/2021**Client Sample ID:** ES 205 Faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 6:54:49 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-009**Collection Date:** 4/5/2021**Client Sample ID:** ES 32 2nd Floor Staff Restroom**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 6:58:31 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-010**Collection Date:** 4/5/2021**Client Sample ID:** ES 206 Faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 7:02:15 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 15-Apr-21

CLIENT: Berne Knox Westerlo School District**LabWork Order:** 210406028**Project:****PO#:** 210310

Elementary Lead

Lab SampleID: 210406028-011**Collection Date:** 4/5/2021**Client Sample ID:** ES 210 DF**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 7:13:25 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-012**Collection Date:** 4/5/2021**Client Sample ID:** ES 210 Faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 7:24:37 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-013**Collection Date:** 4/5/2021**Client Sample ID:** ES 200 DF**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 7:28:21 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-014**Collection Date:** 4/5/2021**Client Sample ID:** ES 200 Faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 7:32:06 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-015**Collection Date:** 4/5/2021**Client Sample ID:** ES 204 Faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 7:35:52 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 15-Apr-21

CLIENT: Berne Knox Westerlo School District**LabWork Order:** 210406028**Project:****PO#:** 210310

Elementary Lead

Lab SampleID: 210406028-016**Collection Date:** 4/5/2021**Client Sample ID:** ES 32 2nd Floor Girl's Right**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 7:39:34 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-017**Collection Date:** 4/5/2021**Client Sample ID:** ES 32 2nd Floor Girl's Left**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 7:43:17 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-018**Collection Date:** 4/5/2021**Client Sample ID:** ES 108 Faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 7:46:59 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-019**Collection Date:** 4/5/2021**Client Sample ID:** ES 108 DF**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 7:58:09 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-020**Collection Date:** 4/5/2021**Client Sample ID:** ES DF 32 2nd Floor East**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 8:01:52 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 15-Apr-21

CLIENT: Berne Knox Westerlo School District**LabWork Order:** 210406028**Project:****PO#:** 210310

Elementary Lead

Lab SampleID: 210406028-021**Collection Date:** 4/5/2021**Client Sample ID:** ES 32 1st Floor DF**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 8:13:03 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-022**Collection Date:** 4/5/2021**Client Sample ID:** ES 105 Faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 8:24:17 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-023**Collection Date:** 4/5/2021**Client Sample ID:** ES 105 DF**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 8:28:02 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-024**Collection Date:** 4/5/2021**Client Sample ID:** ES 104 DF**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 8:31:45 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-025**Collection Date:** 4/5/2021**Client Sample ID:** ES 104 Faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 8:42:55 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 15-Apr-21

CLIENT: Berne Knox Westerlo School District**LabWork Order:** 210406028**Project:****PO#:** 210310

Elementary Lead

Lab SampleID: 210406028-026**Collection Date:** 4/5/2021**Client Sample ID:** ES 32 1st Floor Boys Left**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 8:46:38 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-027**Collection Date:** 4/5/2021**Client Sample ID:** ES 32 1st Floor Boys Right**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 8:50:21 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-028**Collection Date:** 4/5/2021**Client Sample ID:** ES 32 1st Floor Girls Right**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 8:54:04 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-029**Collection Date:** 4/5/2021**Client Sample ID:** ES 32 1st Floor Girls Left**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 8:57:48 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-030**Collection Date:** 4/5/2021**Client Sample ID:** ES Supt Office**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 9:01:31 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 15-Apr-21

CLIENT: Berne Knox Westerlo School District**LabWork Order:** 210406028**Project:****PO#:** 210310

Elementary Lead

Lab SampleID: 210406028-031**Collection Date:** 4/5/2021**Client Sample ID:** ES Nurse Bathroom**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 9:05:15 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-032**Collection Date:** 4/5/2021**Client Sample ID:** ES Nurse Faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 9:16:29 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-033**Collection Date:** 4/5/2021**Client Sample ID:** ES Main Office**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 9:27:41 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-034**Collection Date:** 4/5/2021**Client Sample ID:** ES Art Room Faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 9:31:25 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-035**Collection Date:** 4/5/2021**Client Sample ID:** ES 014 Restroom**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 9:35:09 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 15-Apr-21

CLIENT: Berne Knox Westerlo School District**LabWork Order:** 210406028**Project:****PO#:** 210310

Elementary Lead

Lab SampleID: 210406028-036**Collection Date:** 4/5/2021**Client Sample ID:** ES 32 Ground Floor Restroom**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 9:38:52 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-037**Collection Date:** 4/5/2021**Client Sample ID:** ES Café Faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 9:42:36 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-038**Collection Date:** 4/5/2021**Client Sample ID:** ES Café Fountain**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 9:46:19 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-039**Collection Date:** 4/5/2021**Client Sample ID:** ES Kitchen Cooks Sink**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 9:50:03 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-040**Collection Date:** 4/5/2021**Client Sample ID:** ES Kitchen Rinse Sink**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 9:53:47 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 15-Apr-21

CLIENT: Berne Knox Westerlo School District**LabWork Order:** 210406028**Project:****PO#:** 210310

Elementary Lead

Lab SampleID: 210406028-041**Collection Date:** 4/5/2021**Client Sample ID:** ES Kitchen Sanitize Sink**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 10:12:27 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210406028-042**Collection Date:** 4/5/2021**Client Sample ID:** ES Kitchen Wash Sink**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 10:23:41 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210406028-043**Collection Date:** 4/5/2021**Client Sample ID:** ES 55 Girls Room Left**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 10:27:25 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210406028-044**Collection Date:** 4/5/2021**Client Sample ID:** ES 55 Girls Room Right**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 10:31:08 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210406028-045**Collection Date:** 4/5/2021**Client Sample ID:** ES 55 Boys Room Right**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 10:34:52 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 15-Apr-21

CLIENT: Berne Knox Westerlo School District**LabWork Order:** 210406028**Project:****PO#:** 210310

Elementary Lead

Lab SampleID: 210406028-046**Collection Date:** 4/5/2021**Client Sample ID:** ES 55 Boys Room Left**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 10:38:36 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210406028-047**Collection Date:** 4/5/2021**Client Sample ID:** ES 220 Faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 10:42:20 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210406028-048**Collection Date:** 4/5/2021**Client Sample ID:** ES 220 DF**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 10:46:04 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210406028-049**Collection Date:** 4/5/2021**Client Sample ID:** ES 55 Boys Middle Faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 10:57:15 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210406028-050**Collection Date:** 4/5/2021**Client Sample ID:** ES 222 Faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 11:00:59 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 15-Apr-21

CLIENT: Berne Knox Westerlo School District**LabWork Order:** 210406028**Project:****PO#:** 210310

Elementary Lead

Lab SampleID: 210406028-051**Collection Date:** 4/5/2021**Client Sample ID:** ES 221 Faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 11:04:44 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210406028-052**Collection Date:** 4/5/2021**Client Sample ID:** ES 221 DF**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 11:15:58 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210406028-053**Collection Date:** 4/5/2021**Client Sample ID:** ES 224 Faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 11:19:42 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210406028-054**Collection Date:** 4/5/2021**Client Sample ID:** ES 224 DF**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 11:23:27 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210406028-055**Collection Date:** 4/5/2021**Client Sample ID:** ES 223 Faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 11:27:11 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 15-Apr-21

CLIENT: Berne Knox Westerlo School District**LabWork Order:** 210406028**Project:****PO#:** 210310

Elementary Lead

Lab SampleID: 210406028-056**Collection Date:** 4/5/2021**Client Sample ID:** ES 225 Faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 11:30:55 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210406028-057**Collection Date:** 4/5/2021**Client Sample ID:** ES 225 DF**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 11:42:06 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210406028-058**Collection Date:** 4/5/2021**Client Sample ID:** ES 126 Bathroom**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 11:45:50 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210406028-059**Collection Date:** 4/5/2021**Client Sample ID:** ES 126 DF**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 11:49:35 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210406028-060**Collection Date:** 4/5/2021**Client Sample ID:** ES 126 Faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/13/2021 11:53:19 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 15-Apr-21

CLIENT: Berne Knox Westerlo School District**LabWork Order:** 210406028**Project:****PO#:** 210310

Elementary Lead

Lab SampleID: 210406028-061**Collection Date:** 4/5/2021**Client Sample ID:** ES 125 Faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/14/2021 12:04:34 AM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210406028-062**Collection Date:** 4/5/2021**Client Sample ID:** ES 125 Bathroom**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/14/2021 12:15:47 AM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210406028-063**Collection Date:** 4/5/2021**Client Sample ID:** ES 125 DF**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/14/2021 12:26:59 AM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210406028-064**Collection Date:** 4/5/2021**Client Sample ID:** ES 127 Faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/14/2021 12:30:43 AM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210406028-065**Collection Date:** 4/5/2021**Client Sample ID:** ES 127 DF**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/14/2021 12:34:28 AM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 15-Apr-21

CLIENT: Berne Knox Westerlo School District**LabWork Order:** 210406028**Project:****PO#:** 210310

Elementary Lead

Lab SampleID: 210406028-066**Collection Date:** 4/5/2021**Client Sample ID:** ES 127 Bathroom**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/14/2021 12:38:12 AM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210406028-067**Collection Date:** 4/5/2021**Client Sample ID:** ES 124 Faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/14/2021 12:41:56 AM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210406028-068**Collection Date:** 4/5/2021**Client Sample ID:** ES 124 DF**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/14/2021 12:45:41 AM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210406028-069**Collection Date:** 4/5/2021**Client Sample ID:** ES 124 Bathroom**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/14/2021 12:49:26 AM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210406028-070**Collection Date:** 4/5/2021**Client Sample ID:** ES 122 DF**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/14/2021 12:53:11 AM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 15-Apr-21

CLIENT: Berne Knox Westerlo School District**LabWork Order:** 210406028**Project:****PO#:** 210310

Elementary Lead

Lab SampleID: 210406028-071**Collection Date:** 4/5/2021**Client Sample ID:** ES 122 Faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/14/2021 12:56:56 AM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210406028-072**Collection Date:** 4/5/2021**Client Sample ID:** ES 122 Bathroom**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/14/2021 1:15:37 AM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-073**Collection Date:** 4/5/2021**Client Sample ID:** ES 55 Hall 1st Floor DF**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/14/2021 1:19:22 AM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-074**Collection Date:** 4/5/2021**Client Sample ID:** ES 123 DF**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/14/2021 1:23:07 AM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-075**Collection Date:** 4/5/2021**Client Sample ID:** ES 123 Restroom**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/14/2021 1:26:51 AM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 15-Apr-21

CLIENT: Berne Knox Westerlo School District**LabWork Order:** 210406028**Project:****PO#:** 210310

Elementary Lead

Lab SampleID: 210406028-076**Collection Date:** 4/5/2021**Client Sample ID:** ES 123 Faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/14/2021 1:30:36 AM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-077**Collection Date:** 4/5/2021**Client Sample ID:** ES 121 Faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/14/2021 1:34:21 AM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-078**Collection Date:** 4/5/2021**Client Sample ID:** ES 121 Restroom**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/14/2021 1:38:07 AM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-079**Collection Date:** 4/5/2021**Client Sample ID:** ES 121 DF**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/14/2021 1:41:52 AM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210406028-080**Collection Date:** 4/5/2021**Client Sample ID:** ES 117 DF**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/14/2021 1:45:37 AM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 15-Apr-21

CLIENT: Berne Knox Westerlo School District**LabWork Order:** 210406028**Project:****PO#:** 210310

Elementary Lead

Lab SampleID: 210406028-081**Collection Date:** 4/5/2021**Client Sample ID:** ES 117 Faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/14/2021 2:39:40 PM
------	-----------	-----	--	------	---	----------------------

Lab SampleID: 210406028-082**Collection Date:** 4/5/2021**Client Sample ID:** ES 117 Restroom**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/7/2021)

Lead	ND	1.0		µg/L	1	4/14/2021 2:50:52 PM
------	-----------	-----	--	------	---	----------------------



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

210406028

COC Reference:

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: <u>Berne-Knox-Western</u> <u>CSD</u> <u>(BKWCSD)</u>		Address:					
Send Report to: <u>Keith Domermuth</u>		Project Name (Location): <u>Elem Lead</u>					
Client Phone #: <u>518-822-0846</u>		Client PO #:					
Client Email: <u>Keith.domermuth@bkwcsls.org</u>		Samplers Name: <u>Keith Domermuth</u>					
Samplers Signature: <u>Keith Domermuth</u>							
AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=am P=pm	Sample Type Matrix C G	# of Cont's	Preservative	Analysis
001	ES207 Faucet	4/5/21	1:15	A P			
002	ES204 DF	4/5/21	1:17	A P			
003	ES32 2nd Floor Boys Left	4/5/21	1:20	A P			
004	ES32 2nd Floor Boys Room Right	4/5/21	1:20	A P			
005	ES206 DF	4/5/21	1:21	A P			
006	ES207 DF	4/5/21	1:15	A P			
007	ES205 DF	4/5/21	1:21	A P			
008	ES205 Faucet	4/5/21	1:21	A P			
009	ES32 2nd Floor Staff Room	4/5/21	1:22	A P			
010	ES206 Faucet	4/5/21	1:21	A P			
011	ES210 DF	4/5/21	1:23	A P			
012	ES210 Faucet	4/5/21	1:23	A P			
013	ES200 DF	4/5/21	1:25	A P			
014	ES200 Faucet	4/5/21	1:25	A P			
015	ES204 Faucet	4/5/21	1:17	A P			
Shipment Arrived Via: FedEx UPS <u>Client</u> AES Other:				Special Instructions/Remarks:			
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard NOTE: Samples received after 3:30pm are considered next business day.							
Relinquished by: (Signature) <u>Keith Domermuth</u>				Received by: (Signature) <u>[Signature]</u>		Date <u>4/6/21</u>	Time <u>11:35 am</u>
Relinquished by: (Signature)				Received by: (Signature)		Date	Time
Relinquished by: (Signature)				Received for Laboratory by: <u>[Signature]</u>		Date <u>4/6/21</u>	Time <u>12:03 pm</u>
Sample Temperature Ambient ~ Chilled ~ Chilling Begun Notes: <u>18°C</u>		Properly Preserved: Y / N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other		Received Within Holding Times: Y / N Notes:			
Custody Seal Intact: Y / N							
Bottles AES: Y / N							



210406028



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

210406028

COC Reference:

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: <u>Berne-Knot-Western</u>		Address: <u>1738 Helderberg trail Berne NY</u>							
Send Report to: <u>Keith Demermuth</u>		Project Name (Location): <u>ES Lead</u>	Samplers Name: <u>Keith Demermuth</u>						
Client Phone #: <u>518-872-0946</u>		Client PO #:	Samplers Signature: <u>[Signature]</u>						
Client Email: <u>Keith.Demermuth@BKWschools.org</u>									
AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=am P=pm	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
016	ES 32 ^{2nd} Floor girls Right	4/5/21	1:28	A					
017	ES 32 ^{2nd} Floor girls Left	4/5/21	1:28	A					
018	ES 108 Faucet	4/5/21	1:30	A					
019	ES 108 OF	4/5/21	1:30	A					
020	ES DF 32 2 nd Floor (East)	4/5/21	1:40	A					
021	ES 32 1 st Floor DF	4/5/21	1:38	A					
022	ES 105 Faucet	4/5/21	1:41	A					
023	ES 105 DF	4/5/21	1:41	A					
024	ES 104 OF	4/5/21	1:43	A					
025	ES 104 Faucet	4/5/21	1:43	A					
026	ES 32 1 st Floor Boys Left	4/5/21	1:45	A					
027	ES 32 1 st Floor boys Right	4/5/21	1:45	A					
028	ES 32 1 st Floor girls Right	4/5/21	1:50	A					
029	ES 32 1 st Floor girls Left	4/5/21	1:50	A					
030	ES Supt Office	4/5/21	1:48	A					
Shipment Arrived Via: FedEx UPS <u>Client</u> AES Other:				Special Instructions/Remarks:					
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard NOTE: Samples received after 3:30pm are considered next business day.									
Relinquished by: (Signature)				Received by: (Signature)			Date	Time	
Relinquished by: (Signature)				Received by: (Signature)			Date	Time	
Relinquished by: (Signature)				Received for Laboratory by:			Date	Time	
Sample Temperature Ambient ~ Chilled ~ Chilling Begun				Properly Preserved: Y / N				Received Within Holding Times: Y N	
Notes:				0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other				Notes:	
Custody Seal Intact: Y / N									
Bottles AES: Y / N									



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

210406028

COC Reference:

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: <u>Berne Hook - Western</u> <u>CSD</u>		Address: <u>1738 Helderberg Trail Berne NY 12023</u>					
Send Report to: <u>Keith Domermuth</u>		Project Name (Location): <u>Elm Lead</u>					
Client Phone #: <u>518-832-0446</u>		Client PO #:					
Client Email: <u>Keith.domermuth@berkshireschools.org</u>		Samplers Name: <u>Keith Domermuth</u>					
		Samplers Signature: <u>Keith Domermuth</u>					
AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=am P=pm	Sample Type Matrix C G	# of Cont's	Preservative	Analysis
031	ES Nurse Bathroom	4/5/21	1:45	A P			
032	ES Nurse W Faucet	4/5/21	1:45	A P			
033	ES main office	4/5/21	1:46	A P			
034	ES Art Room Faucet	4/5/21	1:50	A P			
035	ES 014 Restroom	4/5/21	1:51	A P			
036	ES 32 ground floor Restroom	4/5/21	1:53	A P			
037	ES cafe Faucet	4/5/21	2:00	A P			
038	ES cafe Fountain	4/5/21	2:00	A P			
039	ES Kitchen cooks sink	4/5/21	2:05	A P			
040	ES Kitchen Rinse sink	4/5/21	2:05	A P			
041	ES Kitchen sanitize sink	4/5/21	2:05	A P			
042	ES Kitchen wash sink	4/5/21	2:05	A P			
043	ES 55 Girls Room left	4/5/21	2:10	A P			
044	ES 55 Girls Room Right	4/5/21	2:10	A P			
045	ES 55 Boys Room Right	4/5/21	2:15	A P			
Shipment Arrived Via: FedEx UPS <u>Client</u> AES Other:				Special Instructions/Remarks:			
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard NOTE: Samples received after 3:30pm are considered next business day.							
Relinquished by: (Signature)				Received by: (Signature)		Date	Time
						4/6/21	11:35am
Relinquished by: (Signature)				Received by: (Signature)		Date	Time
Relinquished by: (Signature)				Received for Laboratory by:		Date	Time
Sample Temperature Ambient ~ Chilled ~ Chilling Begun		Properly Preserved: Y / N		Received Within Holding Times: Y / N			
Notes:		0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃		5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other			
Custody Seal Intact: Y / N				Notes:			
Bottles AES: Y / N							



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

210406028

COC Reference:

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: <u>Berne-Knox Westerlo CSD</u>	Address: <u>1738 Helderberg Hall Berne NY</u>	
Send Report to: <u>Keith Domermuth</u>	Project Name (Location): <u>Elem lead</u>	Samplers Name: <u>Keith Domermuth</u>
Client Phone #: <u>518-872-0946</u>	Client PO #:	Samplers Signature: <u>Keith Domermuth</u>
Client Email: <u>Keith.domermuth@bnkwschools.org</u>		

AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=am P=pm	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
046	ES 55 Boys Room 1st	4/5/21	2:15	A					
047	ES 220 Faucet	4/5/21	2:18	A					
048	ES 220 DF	4/5/21	2:18	A					
049	ES Boys Middle Rm			A					
050	ES 55 Boys Middle Faucet	4/5/21	2:15	A					
051	ES 222 Faucet	4/5/21	2:16	A					
052	ES 221 Faucet	4/5/21	2:17	A					
053	ES 221 DF	4/5/21	2:17	A					
054	ES 224 Faucet	4/5/21	2:20	A					
055	ES 224 DF	4/5/21	2:20	A					
056	ES 223 Faucet	4/5/21	2:22	A					
057	ES 223 Faucet	4/5/21	2:24	A					
058	ES 223 DF	4/5/21	2:24	A					
059	ES 126 Bathroom	4/5/21	2:35	A					
060	ES 126 DF	4/5/21	2:35	A					

Shipment Arrived Via:

FedEx UPS Client AES Other:

Special Instructions/Remarks:

Turnaround Time Requested:

1 Day 2 Day 3 Day 5 Day Standard

NOTE: Samples received after 3:30pm are considered next business day.

Relinquished by: (Signature)

Received by: (Signature)

Date

Time

Relinquished by: (Signature)

Received by: (Signature)

Date

Time

Relinquished by: (Signature)

Received for Laboratory by:

Date

Time

Sample Temperature

Ambient ~ Chilled ~ Chilling Begun

Properly Preserved: Y / N

0=None 5=NH₄Cl
1=H₂SO₄ pH<2 6=Ascorbic Acid
2=HNO₃ pH<2 7=FAS
3=HCl pH<2 8=ZnAc/NaOH pH>9
4=Na₂S₂O₃ 9=NaOH pH>10
10=Other

Received Within Holding

Times: Y / N

Notes:

Notes:

Custody Seal Intact: Y / N

Bottles AES: Y / N



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

210406028

COC Reference:

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: <u>Borne-Knot-Western CSO</u>	Address: <u>1738 Helderberg Trail Berne NY</u>	
Send Report to: <u>Keith Domermuth</u>	Project Name (Location): <u>Elem 1-eal</u>	Samplers Name: <u>Keith Domermuth</u>
Client Phone #: <u>518-872-0946</u>	Client PO #:	Samplers Signature: <u>Keith Domermuth</u>
Client Email: <u>Keith.Domermuth@BKWschools.org</u>		

AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=am P=pm	Sample Type			# of Cont's	Preser- vative	Analysis
				Matrix	C	G			
060	061 ES 126 Faucet	4/5/21	2:35	A					
061	062 ES 125 Faucet	4/5/21	2:37	A					
062	063 ES 125 Bathroom	4/5/21	2:37	A					
063	064 ES 125 DF	4/5/21	2:37	A					
064	065 ES 127 Faucet	4/5/21	2:40	A					
065	066 ES 127 DF	4/5/21	2:40	A					
066	067 ES 127 Bathroom	4/5/21	2:40	A					
067	068 ES 124 Faucet	4/5/21	2:42	A					
068	069 ES 124 DF	4/5/21	2:42	A					
069	070 ES 124 Bathroom	4/5/21	2:42	A					
070	071 ES 122 DF	4/5/21	2:45	A					
071	072 ES 122 Faucets	4/5/21	2:45	A					
072	073 ES 122 Bathroom	4/5/21	2:45	A					
073	074 ES 55 Hall 1st Floor DF	4/5/21	2:50	A					
074	075 ES 123 DF	4/5/21	2:52	A					

Shipment Arrived Via:

FedEx UPS Client AES Other:

Special Instructions/Remarks:

Turnaround Time Requested:

1 Day 2 Day 3 Day 5 Day Standard

NOTE: Samples received after 3:30pm are considered next business day.

Relinquished by: (Signature)

Relinquished by: (Signature)

Relinquished by: (Signature)

Received by: (Signature)

Received by: (Signature)

Received for Laboratory by:

Date

Time

Date

Time

Date

Time

Sample Temperature

Ambient ~ Chilled ~ Chilling Begun

Notes:

Properly Preserved: Y / N

0=None
1=H₂SO₄ pH<2
2=HNO₃ pH<2
3=HCl pH<2
4=Na₂S₂O₃
5=NH₄Cl
6=Ascorbic Acid
7=FAS
8=ZnAc/NaOH pH>9
9=NaOH pH>10
10=Other

Received Within Holding

Times: Y / N

Notes:

Custody Seal Intact: Y / N

Bottles AES: Y / N



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

210406028

COC Reference:

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: <u>Berne-Knox-Western CSD</u>	Address: <u>1738 Itelderberg Trail Berne NY 12023</u>	
Send Report to: <u>Keith Donermuth</u>	Project Name (Location): <u>Elem Lead</u>	Samplers Name: <u>Keith Donermuth</u>
Client Phone #: <u>518-872-0946</u>	Client PO #:	Samplers Signature: <u>Keith Donermuth</u>
Client Email:		

AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=am P=pm	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
075	ES123 Restroom	4/5/21	2:52	A					
076	ES123 Faucet	4/5/21	2:52	A					
079	ES121 Faucet	4/5/21	2:58	A					
078	ES121 Restroom	4/5/21	2:59	A					
079	ES121 DF	4/5/21	2:58	A					
080	ES117 DF	4/5/21	3:00	A					
081	ES117 Faucet	4/5/21	3:00	A					
082	ES117 Restroom	4/5/21	3:00	A					
				A					
				P					
				A					
				P					
				A					
				P					
				A					
				P					
				A					
				P					
				A					
				P					

Shipment Arrived Via:

FedEx UPS Client AES Other:

Special Instructions/Remarks:

Turnaround Time Requested:

1 Day 2 Day 3 Day 5 Day Standard

NOTE: Samples received after 3:30pm are considered next business day.

Relinquished by: (Signature)

Received by: (Signature)

Date

Time

Relinquished by: (Signature)

Received by: (Signature)

Date

Time

Relinquished by: (Signature)

Received for Laboratory by:

Date

Time

Sample Temperature

Ambient ~ Chilled ~ Chilling Begun

Notes:

Properly Preserved: Y / N

0=None 5=NH₄Cl
1=H₂SO₄ pH<2 6=Ascorbic Acid
2=HNO₃ pH<2 7=FAS
3=HCl pH<2 8=ZnAc/NaOH pH>9
4=Na₂S₂O₃ 9=NaOH pH>10
10=Other

Received Within Holding Times: Y / N

Notes:

Custody Seal Intact: Y / N

Bottles AES: Y / N



Experience is the solution

314 North Pearl Street • Albany, New York 12207 • (518) 434-4546 • Fax (518) 434-0891

TERMS, CONDITIONS & LIMITATIONS

All service rendered by the **Adirondack Environmental Services, Inc.** are undertaken and all rates are based upon the following terms:

- (a) Neither **Adirondack Environmental Services, Inc.**, nor any of its employees, agents or sub-contractors shall be liable for any loss or damage arising out of **Adirondack Environmental Services, Inc.**'s performance or nonperformance, whether by way of negligence or breach of contract, or otherwise, in any amount greater than twice the amount billed to the customer for the work leading to the claim of the customer. Said remedy shall be the sole and exclusive remedy against **Adirondack Environmental Services, Inc.** arising out of its work.
- (b) All claims made must be in writing within forty-five (45) days after delivery of the **Adirondack Environmental Services, Inc.** report regarding said work or such claim shall be deemed or irrevocably waived.
- (c) **Adirondack Environmental Services, Inc.** reports are submitted in writing and are for our customers only. Our customers are considered to be only those entities being billed for our services. Acquisition of an **Adirondack Environmental Services, Inc.** report by other than our customer does not constitute a representation of **Adirondack Environmental Services, Inc.** as to the accuracy of the contents thereof.
- (d) In no event shall **Adirondack Environmental Services, Inc.**, its employees, agents or sub-contractors be responsible for consequential or special damages of any kind or in any amount.
- (e) No deviation from the terms set forth herein shall bind **Adirondack Environmental Services, Inc.** unless in writing and signed by a Director of **Adirondack Environmental Services, Inc.**
- (f) Results pertain only to items analyzed. Information supplied by client is assumed to be correct. This information may be used on reports and in calculations and **Adirondack Environmental Services, Inc.** is not responsible for the accuracy of this information.
- (g) Payments by Credit Card/Purchase Cards are subject to a 3% additional charge.