



Experience is the solution

314 North Pearl Street ♦ Albany, New York 12207
(800) 848-4983 ♦ (518) 434-4546 ♦ Fax (518) 434-0891

December 04, 2025

Keith Domermuth
Berne Knox Westerlo School District
1738 Helderberg Trail
Berne, NY 12308

TEL: (518) 872-1117

Work Order No: 251125004
PO#: 210310

RE:
HS Lead

Adirondack Environmental Services, Inc received 85 samples on 11/25/2025 for the analyses presented in the following report.

Please see case narrative for specifics on analysis.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,

ELAP#: 10709

Tara Daniels
Laboratory Director

Adirondack Environmental Services, Inc

CASE NARRATIVE

Berne Knox Westerlo School District

Date: 04-Dec-25

HS Lead

Lab WorkOrder: 251125004

Sample containers were supplied by Adirondack Environmental Services.

Definitions - RL: Reporting Limit DF: Dilution factor

Qualifiers:	ND : Not Detected at reporting limit	C: CCV below acceptable Limits
	J: Analyte detected below quantitation limit	C+: CCV above acceptable Limits
	B: Analyte detected in Blank	S: LCS Spike recovery is below acceptable limits
	X : Exceeds maximum contamination limit	S+: LCS Spike recovery is above acceptable limits
	H: Hold time exceeded	Z: Duplication outside acceptable limits
	N: Matrix Spike below acceptable limits	T : Tentatively Identified Compound-Estimated
	N+: Matrix Spike is above acceptable limits	E :Above quantitation range-Estimated

Note : All Results are reported as wet weight unless noted

The results relate only to the items tested. Information supplied by the client is assumed to be correct.

Adirondack Environmental Services, Inc

Date: 04-Dec-25

CLIENT: Berne Knox Westerlo School District**LabWork Order:** 251125004**Project:**
HS Lead**PO#:** 210310**Lab SampleID:** 251125004-001**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS Girls Coaches Faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:09:45 AM)

Lead	ND	1.0		µg/L	1	12/2/2025 11:10:02 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251125004-002**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS Kitchen Hand Wash**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:09:45 AM)

Lead	ND	1.0		µg/L	1	12/2/2025 11:28:02 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251125004-003**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS Kitchen sanitize**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:09:45 AM)

Lead	ND	1.0		µg/L	1	12/2/2025 11:31:39 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251125004-004**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS Kitchen prep faucet 2**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:09:45 AM)

Lead	ND	1.0		µg/L	1	12/2/2025 11:35:15 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251125004-005**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS Kitchen Steam kettle**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:09:45 AM)

Lead	ND	1.0		µg/L	1	12/2/2025 11:38:52 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 04-Dec-25

CLIENT: Berne Knox Westerlo School District**LabWork Order:** 251125004**Project:**
HS Lead**PO#:** 210310**Lab SampleID:** 251125004-006**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS 1st floor 65 DF 2 south**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:09:45 AM)

Lead	ND	1.0		µg/L	1	12/2/2025 11:42:28 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251125004-007**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS Girls locker room 2**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:09:45 AM)

Lead	ND	1.0		µg/L	1	12/2/2025 11:46:05 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251125004-008**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS Kitchen Wash**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:09:45 AM)

Lead	ND	1.0		µg/L	1	12/2/2025 11:49:41 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251125004-009**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS Kitchen Prep sink 1**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:09:45 AM)

Lead	ND	1.0		µg/L	1	12/2/2025 11:53:18 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251125004-010**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS Boys locker room #2**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:09:45 AM)

Lead	ND	1.0		µg/L	1	12/2/2025 11:56:54 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 04-Dec-25

CLIENT: Berne Knox Westerlo School District**LabWork Order:** 251125004**Project:****PO#:** 210310

HS Lead

Lab SampleID: 251125004-011**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS Gym locker room fountain**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:09:45 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 12:07:41 AM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251125004-012**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS Cafe girls faucet let**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:09:45 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 12:18:32 AM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251125004-013**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS Kitchen Restroom**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:09:45 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 12:22:09 AM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251125004-014**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS Cafe boys faucet left**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:09:45 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 12:25:46 AM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251125004-015**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** SH 1st floor boys 65 Faucet 2**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:09:45 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 12:29:23 AM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 04-Dec-25

CLIENT: Berne Knox Westerlo School District**LabWork Order:** 251125004**Project:**
HS Lead**PO#:** 210310**Lab SampleID:** 251125004-016**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS 1st Floor boys 65 Faucet 3**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:09:45 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 12:33:00 AM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251125004-017**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS 1st floor 65 DF South**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:09:45 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 12:36:36 AM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251125004-018**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS Cafe DF**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:09:45 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 12:40:13 AM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251125004-019**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS 1st floor unisex faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:09:45 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 12:51:01 AM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251125004-020**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS 1st floor 65 girls faucet 1**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:09:45 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 12:54:38 AM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 04-Dec-25

CLIENT: Berne Knox Westerlo School District**LabWork Order:** 251125004**Project:**
HS Lead**PO#:** 210310**Lab SampleID:** 251125004-021 **Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS 1st Floor 65 girls faucet 2 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:45 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 1:05:29 AM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-022 **Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS 1st Floor 65 girls faucet 3 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:45 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 1:16:20 AM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-023 **Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS nurse faucet 1 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:45 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 1:19:58 AM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-024 **Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS nurse faucet 3 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:45 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 1:23:35 AM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-025 **Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS 1st floor 65 boys faucet **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:45 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 12:28:47 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 04-Dec-25

CLIENT: Berne Knox Westerlo School District**LabWork Order:** 251125004**Project:**
HS Lead**PO#:** 210310**Lab SampleID:** 251125004-026**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS MDF Faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:45 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 12:32:24 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251125004-027**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS Kitchen Rinse**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:45 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 12:36:01 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251125004-028**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS Cafe boys faucet 1**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:45 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 12:39:38 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251125004-029**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS Cafe DF Left**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:45 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 12:43:14 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251125004-030**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS Industrial Arts faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:45 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 12:46:51 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 04-Dec-25

CLIENT: Berne Knox Westerlo School District**LabWork Order:** 251125004**Project:**
HS Lead**PO#:** 210310**Lab SampleID:** 251125004-031**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS Boys coaches faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:45 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 12:50:28 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251125004-032**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS BOys Locker Room**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:45 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 1:01:18 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-033**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS weight room faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:45 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 1:12:05 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-034**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS Ag Faucet 1**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:45 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 1:15:42 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-035**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS Ag Faucet 2**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:45 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 1:19:19 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 04-Dec-25

CLIENT: Berne Knox Westerlo School District**LabWork Order:** 251125004**Project:**
HS Lead**PO#:** 210310**Lab SampleID:** 251125004-036**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS 96 Staff RR 1st floor left**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:45 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 1:22:55 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-037**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS 96 Staff RR 1st floor right**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:45 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 1:26:32 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-038**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS Home Ec Faucet 1**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:45 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 1:30:09 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-039**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS Home Ec Faucet 2**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:45 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 1:33:46 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-040**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS Home Ec Faucet 3**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:45 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 1:37:23 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 04-Dec-25

CLIENT: Berne Knox Westerlo School District**LabWork Order:** 251125004**Project:**
HS Lead**PO#:** 210310**Lab SampleID:** 251125004-041**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS 1 GT Faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:48 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 1:55:24 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-042**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS 96 2nd floor RR Left**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:48 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 2:06:16 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-043**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS 96 2nd floor RR Right**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:48 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 2:09:53 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-044**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS 96 2nd floor DF**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:48 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 2:13:30 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-045**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS 217 Faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:48 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 2:17:07 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 04-Dec-25

CLIENT: Berne Knox Westerlo School District
Project: HS Lead

LabWork Order: 251125004
PO#: 210310

Lab SampleID: 251125004-046 **Collection Date:** 11/23/2025 6:00:00 AM

Client Sample ID: HS 65 2nd floor womens staff R **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 11/25/2025 11:11:48 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 2:20:45 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-047 **Collection Date:** 11/23/2025 6:00:00 AM

Client Sample ID: HS 96 1st floor DF **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 11/25/2025 11:11:48 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 2:24:22 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-048 **Collection Date:** 11/23/2025 6:00:00 AM

Client Sample ID: HS 65 2nd floor bas faucet 1 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 11/25/2025 11:11:48 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 2:27:59 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-049 **Collection Date:** 11/23/2025 6:00:00 AM

Client Sample ID: HS 65 2nd Floor bas Faucet 2 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 11/25/2025 11:11:48 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 2:38:46 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-050 **Collection Date:** 11/23/2025 6:00:00 AM

Client Sample ID: HS 65 2nd Floor girls faucet 2 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 11/25/2025 11:11:48 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 2:42:23 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 04-Dec-25

CLIENT: Berne Knox Westerlo School District**LabWork Order:** 251125004**Project:**
HS Lead**PO#:** 210310**Lab SampleID:** 251125004-051**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS 222 Faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:48 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 2:46:01 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-052**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS 65 2nd floor mens faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:48 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 2:56:53 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-053**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS 65 2nd floor DF**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:48 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 3:00:31 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-054**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS 203 Faucet 1**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:48 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 3:04:09 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-055**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS 203 Faucet 2**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:48 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 3:07:46 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 04-Dec-25

CLIENT: Berne Knox Westerlo School District**LabWork Order:** 251125004**Project:**
HS Lead**PO#:** 210310**Lab SampleID:** 251125004-056**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS 203 Faucet 3**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:48 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 3:11:24 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-057**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS 203 Faucet 4**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:48 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 3:22:11 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-058**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS Art faucet 1**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:48 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 3:25:48 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-059**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS Art Faucet 2**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:48 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 3:29:26 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-060**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS 209 Faucet 1**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:48 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 3:33:03 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 04-Dec-25

CLIENT: Berne Knox Westerlo School District**LabWork Order:** 251125004**Project:**
HS Lead**PO#:** 210310**Lab SampleID:** 251125004-061**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS 209 Faucet 2**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:50 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 3:43:58 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-062**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS 209 Faucet 3**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:50 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 3:54:52 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-063**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS 209 Faucet 4**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:50 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 4:05:39 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-064**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS 209 Faucet 5**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:50 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 4:09:17 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-065**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS 210 Faucet 1**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:50 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 4:12:55 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 04-Dec-25

CLIENT: Berne Knox Westerlo School District**LabWork Order:** 251125004**Project:**
HS Lead**PO#:** 210310**Lab SampleID:** 251125004-066**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS 210 Faucet 2**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:50 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 4:16:33 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-067**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS 210 Faucet 3**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:50 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 4:20:11 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-068**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS 210 Faucet 4**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:50 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 4:23:49 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-069**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** 227 Faucet 1**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:50 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 4:27:28 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-070**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** 227 Faucet 2**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:50 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 4:31:06 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 04-Dec-25

CLIENT: Berne Knox Westerlo School District**LabWork Order:** 251125004**Project:**
HS Lead**PO#:** 210310**Lab SampleID:** 251125004-071**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** 227 Faucet 3**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:50 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 4:34:45 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-072**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** 227 Faucet 4**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:50 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 4:52:49 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-073**Collection Date:** 11/23/2025 5:00:00 AM**Client Sample ID:** HS 227 Facuet 5**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:50 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 4:56:28 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-074**Collection Date:** 11/23/2025 5:00:00 AM**Client Sample ID:** HS 227 Faucet 6**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:50 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 5:00:06 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-075**Collection Date:** 11/23/2025 5:00:00 AM**Client Sample ID:** HS 227 Faucet 7**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:50 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 5:03:45 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 04-Dec-25

CLIENT: Berne Knox Westerlo School District**LabWork Order:** 251125004**Project:**
HS Lead**PO#:** 210310**Lab SampleID:** 251125004-076**Collection Date:** 11/23/2025 5:00:00 AM**Client Sample ID:** HS 227 Faucet 8**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:50 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 5:07:23 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-077**Collection Date:** 11/23/2025 5:00:00 AM**Client Sample ID:** HS 227 Faucet 9**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:50 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 5:11:01 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-078**Collection Date:** 11/23/2025 5:00:00 AM**Client Sample ID:** HS 227 Faucet 11**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:50 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 5:14:39 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-079**Collection Date:** 11/23/2025 5:00:00 AM**Client Sample ID:** HS 227 Faucet 12**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:50 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 5:25:28 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-080**Collection Date:** 11/23/2025 5:00:00 AM**Client Sample ID:** HS 227 Faucet 13**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:11:50 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 5:29:06 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 04-Dec-25

CLIENT: Berne Knox Westerlo School District**LabWork Order:** 251125004**Project:**
HS Lead**PO#:** 210310**Lab SampleID:** 251125004-081**Collection Date:** 11/23/2025 5:00:00 AM**Client Sample ID:** HS 227 Faucet 14**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:13:36 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 5:32:45 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-082**Collection Date:** 11/23/2025 5:00:00 AM**Client Sample ID:** HS Weight room DF**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:13:36 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 5:43:41 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-083**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS Trans office mens faucet**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:13:36 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 5:47:19 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-084**Collection Date:** 11/23/2025 6:00:00 AM**Client Sample ID:** HS Trans office womens**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:13:36 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 5:50:58 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 251125004-085**Collection Date:** 11/23/2025 5:00:00 AM**Client Sample ID:** HS Cafe boys faucet 2**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 11/25/2025 11:13:36 AM)

Lead	ND	1.0		µg/L	1	12/3/2025 5:54:37 PM
------	----	-----	--	------	---	----------------------



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

Start 3:20A Finish 5:50AM

10 of 15

CF

CHAIN OF CUSTODY RECORD

AES Work Order#:

251125004

COC Reference:

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: <u>Berne-Knox-Western CO</u>	Address: <u>1738 Heldorberg Trail Berne NY 12023</u>	
Send Report to: <u>Keith Domermuth</u>	Project Name (Location): <u>HS Lead</u>	Samplers Name: <u>Keith Domermuth</u>
Client Phone #: <u>838-202-0687</u>	Client PO #:	Samplers Signature: <u>[Signature]</u>
Client Email: <u>Keith.domermuth@bkwscs.org</u>		

AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=am P=pm	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
001	HS girls coaches faucet	11/23	3:36	P					Lead ↓
002	HS Kitchen Hand Wash			P					
003	HS Kitchen sanitize			P					
004	HS Kitchen Prep Faucet 2			P					
005	HS Kitchen Steam Kettle			P					
006	HS 1st Floor GS DF 2nd			P					
007	HS girls Locker Room 2			P					
	HS Kitchen Steam Kettle			P					
	HS 1st Floor GS			P					
008	HS Kitchen Wash			P					
009	HS Kitchen Prep Sink 1			P					
010	HS Boys Locker Room #2			P					
011	HS gym Locker Room Fountain			P					
012	HS cafe girls faucet hot			P					
013	HS Kitchen Restroom			P					

Shipment Arrived Via: FedEx UPS <u>Client</u> AES Other:		Special Instructions/Remarks:		
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard NOTE: Samples received after 3:30pm are considered next business day.				
Relinquished by: (Signature)				
Relinquished by: (Signature)		Received by: (Signature)	Date	Time
Relinquished by: (Signature)		Received by: (Signature)	Date	Time
Relinquished by: (Signature)		Received for Laboratory by:	Date	Time
Sample Temperature Ambient ~ Chilled ~ Chilling Begun Notes: <u>16</u>		Properly Preserved: Y / N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other		Received Within Holding Times: Y N Notes:
Custody Seal Intact: Y N				
Bottles AES: Y N				



251125004



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

2056
751125004

COC Reference:

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: <u>Berne-Knox-western CSO</u>	Address: <u>1738 Helderberg trail Berne NY 12023</u>	
Send Report to: <u>Keith Domermuth</u>	Project Name (Location): <u>HS Lead</u>	Samplers Name: <u>Keith Domermuth</u>
Client Phone #: <u>518-202-0687</u>	Client PO #:	Samplers Signature:
Client Email: <u>Keith.Domermuth@hillschools.org</u>		

AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=am P=pm	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
014	HS cafe boys Faucet 1	11/23	3-6	P					
015	HS 1st Floor Boys GS Faucet 2			P					
016	HS 1st Floor Boys GS Faucet 3			P					
017	HS 1st Floor GS DP Sinks			P					
018	HS cafe DP			P					
019	HS 1st Floor UNisex Faucet			P					
020	HS 1st Floor GS girls Faucet 1			P					
021	HS 1st Floor GS girls Faucet 2			P					
022	HS 1st Floor GS girls Faucet 3			P					
023	HS NURSE Faucet 1			P					
024	HS NURSE Faucet 3			P					
025	HS 1st Floor GS Boys Faucet 1			P					
026	HS MOD Faucet			P					
027	HS Kitchen Sink			P					
	HS cafe Boys Faucet 2			P					

Shipment Arrived Via: FedEx UPS <u>Client</u> AES Other: _____		Special Instructions/Remarks:			
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard NOTE: Samples received after 3:30pm are considered next business day.					
Relinquished by: (Signature) _____					
Relinquished by: (Signature) _____		Received by: (Signature) _____	Date _____	Time _____	
Relinquished by: (Signature) _____		Received by: (Signature) _____	Date _____	Time _____	
Relinquished by: (Signature) _____		Received for Laboratory by:	Date <u>11/25/23</u>	Time <u>8:52</u>	
Sample Temperature Ambient <u>11</u> Chilled ~ Chilling Begun		Properly Preserved: <u>Y</u> N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other _____		Received Within Holding Times: <u>Y</u> / N	
Notes: _____		Notes: _____			
Custody Seal Intact: <u>Y</u> / N					
Bottles AES: <u>Y</u> / N					



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

3 of 6

CHAIN OF CUSTODY RECORD

AES Work Order#:

2S1125004

COC Reference:

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: Berne-Knox-Westerlo CSD	Address: 1738 Helderberg Trail Berne NY 12023	
Send Report to: Keith Demermuth	Project Name (Location): HS Lead	Samplers Name: Keith Demermuth
Client Phone #: 838-202-0691	Client PO #:	Samplers Signature:
Client Email: Keith.Demermuth@bknwschools.org		

AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=am P=pm	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
028	HS Cafe Boys Faucet 1	11/23	3P	P					
029	HS Cafe DF Left			P					
030	HS Industrial Arts Faucet			P					
031	HS Boys Coaches Faucet			P					
032	HS Boys Locker Room			P					
033	HS Weight Room Faucet			P					
034	HS Ag Faucet 1			P					
035	HS Ag Faucet 2			P					
036	HS 96 Staff RR 1st Floor Left			P					
037	HS 96 Staff RR 1st Floor Right			P					
038	HS Home EC Faucet 1			P					
039	HS Home EC Faucet 2			P					
040	HS Home EC Faucet 3			P					
041	HS 16Y Faucet			P					
042	HS 96 2nd Floor RR Left			P					

Shipment Arrived Via:

FedEx UPS Client AES Other:

Special Instructions/Remarks:

Turnaround Time Requested:

1 Day 2 Day 3 Day 5 Day Standard

NOTE: Samples received after 3:30pm are considered next business day.

Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received for Laboratory by:	Date	Time

11/25/25 8:52

Sample Temperature Ambient ~ Chilled ~ Chilling Begun Notes: 116	Properly Preserved: Y / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other	Received Within Holding Times: Y / N Notes:
Custody Seal Intact: Y / N		
Bottles AES: Y / N		



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

2S112S004

COC Reference:

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: <u>Berne-Knox-Western CSD</u>	Address: <u>1738 Helderberg trail Berne</u>	
Send Report to: <u>Keith Domermuth</u>	Project Name (Location): <u>HS Lead</u>	Samplers Name: <u>Keith Domermuth</u>
Client Phone #: <u>838-202-0687</u>	Client PO #:	Samplers Signature:
Client Email: <u>Keith.Domermuth@bkwschools.org</u>		

AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=am P=pm	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
043	HS 96 2 nd Floor RR Right	11/23	3-6	P					
044	HS 96 2 nd Floor DF			P					
045	HS 217 Faucet			P					
046	HS 65 2 nd Floor Staff RR			P					
047	HS 96 1 st Floor OF			P					
048	HS 65 2 nd Floor boys Faucet 1			P					
049	HS 65 2 nd Floor boys Faucet 2			P					
050	HS 65 2 nd Floor girls Faucet 2			P					
051	HS 222 Faucet			P					
052	HS 65 2 nd Floor Mens Faucet			P					
053	HS 65 2 nd Floor DF			P					
054	HS 203 Faucet 1			P					
055	HS 203 Faucet 2			P					
056	HS 203 Faucet 3			P					
057	HS 203 Faucet 4			P					

Shipment Arrived Via: FedEx UPS Client AES Other:		Special Instructions/Remarks:		
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day <u>Standard</u>				
NOTE: Samples received after 3:30pm are considered next business day.				
Relinquished by: (Signature)		Received by: (Signature)	Date	Time
Relinquished by: (Signature)		Received by: (Signature)	Date	Time
Relinquished by: (Signature)		Received for Laboratory by:	Date	Time
Sample Temperature Ambient ~ Chilled ~ Chilling Begun Notes: <u>16</u>		Properly Preserved: <u>Y</u> / N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other		Received Within Holding Times: <u>Y</u> / N
Custody Seal Intact: <u>Y</u> / N		Notes:		
Bottles AES: <u>Y</u> / N				



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

251125004

COC Reference:

A full service analytical research laboratory offering solutions to environmental concerns

Client Name:	Bernie-Knox-Westfield CSD		Address:	1738 Heidelberg Trail Bernie NY 12023	
Send Report to:	Keith Domermuth		Project Name (Location):	HS Lead	
Client Phone #:	838-202-0687		Samplers Name:	Keith Domermuth	
Client Email:	Keith.domermuth@bkwschools.org		Samplers Signature:		

AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=am P=pm	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
058	HS ART Faucet 1	11/23	3:46	P					
059	HS ART Faucet 2			P					
060	HS 209 Faucet 1			P					
061	HS 209 Faucet 2			P					
062	HS 209 Faucet 3			P					
063	HS 209 Faucet 4			P					
064	HS 209 Faucet 5			P					
065	HS 210 Faucet 1			P					
066	HS 210 Faucet 2			P					
067	HS 210 Faucet 3			P					
068	HS 210 Faucet 4			P					
069	HS 227 Faucet 1			P					
070	HS 227 Faucet 2			P					
071	HS 227 Faucet 3			P					
072	HS 227 Faucet 4			P					

Shipment Arrived Via: FedEx UPS Client AES Other: _____

Turnaround Time Requested:

1 Day 2 Day 3 Day 5 Day Standard

NOTE: Samples received after 3:30pm are considered next business day.

Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received for Laboratory by:	Date	Time

Sample Temperature Ambient ~ Chilled ~ Chilling Begun Notes: <u>116</u>	Properly Preserved: <u>N</u> 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other _____	Received Within Holding Times: <u>Y</u> / N Notes:
Custody Seal Intact: <u>Y</u> / N		
Bottles AES: <u>Y</u> / N		



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#: 251125004

COC Reference:

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: Berne-Knox-Western (CSO)	Address: 1738 Helderberg Trail Berne NY 12023	
Send Report to: Keith Domermuth	Project Name (Location): HS Lead	Samplers Name: Keith Domermuth
Client Phone #: 838-202-0687	Client PO #:	Samplers Signature:
Client Email: Keith.domermuth@bkwschools.org		

AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=am P=pm	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
073	227 Faucet 5	11/23/25	5-	P					
074	227 Faucet 6	11/23/25	5-	P					
075	227 Faucet 7	11/23/25	5-	P					
076	227 Faucet 8	11/23/25	5-	P					
077	227 Faucet 9	11/23/25	5-	P					
078	227 Faucet 11	11/23/25	5-	P					
079	227 Faucet 12	11/23/25	5-	P					
080	227 Faucet 13	11/23/25	5-	P					
081	227 Faucet 14	11/23/25	5-	P					
082	Weight Room DF	11/23/25	5-	P					
083	TRANS MENS -facter	11/23/25	6	P					
084	trans office womens	11/23/25	6	P					
085	HS Cafe Boys Faucet 2	11/23/25	5	P					
				A					
				P					
				A					
				P					

Shipment Arrived Via: FedEx UPS Client AES Other:		Special Instructions/Remarks:	
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard			
NOTE: Samples received after 3:30pm are considered next business day.			
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received for Laboratory by:	Date	Time
Sample Temperature Ambient ~ Chilled ~ Chilling Begun		Properly Preserved: Y / N	
Notes:		0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other	
Custody Seal Intact: Y / N		Received Within Holding Times: Y / N	
Bottles AES: Y / N		Notes:	



Experience is the solution

314 North Pearl Street • Albany, New York 12207 • (518) 434-4546 • Fax (518) 434-0891

TERMS, CONDITIONS & LIMITATIONS

All service rendered by the **Adirondack Environmental Services, Inc.** are undertaken and all rates are based upon the following terms:

- (a) Neither **Adirondack Environmental Services, Inc.**, nor any of its employees, agents or sub-contractors shall be liable for any loss or damage arising out of **Adirondack Environmental Services, Inc.**'s performance or nonperformance, whether by way of negligence or breach of contract, or otherwise, in any amount greater than twice the amount billed to the customer for the work leading to the claim of the customer. Said remedy shall be the sole and exclusive remedy against **Adirondack Environmental Services, Inc.** arising out of its work.
- (b) All claims made must be in writing within forty-five (45) days after delivery of the **Adirondack Environmental Services, Inc.** report regarding said work or such claim shall be deemed or irrevocably waived.
- (c) **Adirondack Environmental Services, Inc.** reports are submitted in writing and are for our customers only. Our customers are considered to be only those entities being billed for our services. Acquisition of an **Adirondack Environmental Services, Inc.** report by other than our customer does not constitute a representation of **Adirondack Environmental Services, Inc.** as to the accuracy of the contents thereof.
- (d) In no event shall **Adirondack Environmental Services, Inc.**, its employees, agents or sub-contractors be responsible for consequential or special damages of any kind or in any amount.
- (e) No deviation from the terms set forth herein shall bind **Adirondack Environmental Services, Inc.** unless in writing and signed by a Director of **Adirondack Environmental Services, Inc.**
- (f) Results pertain only to items analyzed. Information supplied by client is assumed to be correct. This information may be used on reports and in calculations and **Adirondack Environmental Services, Inc.** is not responsible for the accuracy of this information.
- (g) Payments by Credit Card/Purchase Cards are subject to a 3% additional charge.